

EXHIBIT C

**Statement of Work
Water Treatment Systems for the Exterior Pond
and
Potomac Water Feature in 8th floor**

1. The Contactor's service proposal shall include, at a minimum, the following service visits:
 - a) **Monthly (twelve times per year):**
 - TVC's check for the Potomac water feature.
 - Check the chemical pot of the Potomac water feature.
 - Record temperature, PH, Conductivity & Bromine, visual contamination, conductivity for the Potomac Water Feature.
 - b) **Quarterly (four times per year):**
 - Legionella water sampling (Pond and Potomac water feature).
 - Check the Chlorine Residual in the Potomac water feature.
 - a) **Annual (one time per year):**
 - Clean and Chlorination of the Potomac water feature in accordance with British Standards.